

- the work involved;
- the person undertaking the work;
- what they are wearing (such as personal protective equipment); and
- air movement.

Advice and support

For additional advice and support, contact your NASUWT Local Association or NASUWT Scotland Centre.

Contact details can be found:

- on the NASUWT website at www.nasuwt.org.uk;
- in the NASUWT diary; or
- by phoning 0131 226 8480.

Further information

More detailed guidance is available from the HSE at www.hse.gov.uk/temperature.

- the NASUWT website at www.nasuwt.org.uk/HealthAndSafety;
- advice@mail.nasuwt.org.uk.

NASUWT Scotland

35 Young Street North Lane
Edinburgh
EH2 4JD

Tel: 0131 226 8480

E-mail: rc-scotland@mail.nasuwt.org.uk

Website: www.nasuwt.org.uk

The fastest growing teachers' union in Scotland

16/07022 Scotland

Heating and Ventilation



health&safety
at work

The fastest growing teachers' union in Scotland

This leaflet provides essential information relating to minimum and maximum workplace temperatures and heating and ventilation issues.

Legislation and the working environment

The Workplace (Health, Safety and Welfare) Regulations 1992 apply to all workplaces, including schools and colleges, and stipulate that temperatures during working hours shall be 'reasonable'.

Recommended temperatures

Schools should consider the needs of pupils and staff with limited mobility and who may not generate as much body heat as a fully mobile person and may therefore need higher room temperatures.

At the same time, pupils who are hyperactive may need relatively cool environments.

These are issues which should be considered during the maintenance or installation of heating and ventilation systems.

Schools should also explore ways of managing room temperatures by the use of, for example, fans, blinds and additional heating/cooling equipment.

The School Premises (General Requirements and Standards) (Scotland) Regulations 1967 stipulate the following minimum temperatures:

Medical room; changing room; bathroom; WC; shower room	18.5°C
Teaching space; dining room; nursery room; common/staff room	17°C
Assembly room; lecture hall; theatre and cinema	15.5°C
Sickroom	14°C
Cloakroom and corridors	13°C
Gymnasia	13°C
Games hall	10°C

Recommended Summer temperatures

While there are no statutory upper limits on working temperatures, the World Health Organization recommends 24°C as a maximum temperature for comfortable working.

Research has shown pupils ability to learn is significantly impacted upon by high temperatures, with almost a 20% drop in results at 27°C compared to 22°C.

Peak air temperatures should not exceed 28°C during normal working hours.

Excessive working temperatures

The Health and Safety Executive (HSE) affirms that employers are required by the Health and Safety at Work Act 1974 to ensure, so far as is reasonably practicable, the health, safety and welfare of their employees. This, taken together with the provisions set out above under 'Legislation and the working environment', with the requirement for employers to make a suitable assessment of the risks to the health and safety of their workers and to take any necessary, reasonably practicable action to mitigate those risks, means that it is unacceptable for schools to require teachers to work in unreasonably high or low temperatures.

Sufficient thermometers must be provided so that temperatures may be checked and a record kept. Should an unacceptable rise or fall in temperature occur, then the employer should, in consultation with the NASUWT Representative, put in place appropriate emergency measures, which could be:

- the provision of temporary (and safe) heaters which do not introduce fumes into the workplace;
- the provision of suitable alternative room(s); and
- closure or partial closure of the building.

If the employer is unwilling or unable to provide a solution which would be considered reasonable in the particular circumstances, advice from the NASUWT should be sought.

VENTILATION

The importance of adequate ventilation

A supply of fresh air in classrooms is essential. Working in a high temperature can lead to loss of concentration, irritability, headaches, tiredness and discomfort. It can make people more vulnerable to accidents and affect the quality of their work. All practical measures must be taken to protect against fumes, dust and other impurities.

Ventilation within hygiene areas is particularly important as these are areas which often have problems of poor air quality.

The Regulations state that workplaces should be sufficiently well ventilated so that stale, hot or humid air is replaced at a reasonable rate, whilst not causing a draught.

The fresh-air supply rate should not fall below five to eight litres per second per occupant.

If an area, e.g. washrooms, changing rooms or cloakrooms, cannot provide adequate cross-ventilation (i.e. six changes of air per hour) by natural means, then it should be mechanically ventilated.

Excessive temperatures should be reported to the NASUWT Representative who should record daily temperature readings and make representations to the employer where necessary.

In deciding what is a reasonable workplace temperature, employers need to consider a wide range of factors including:

- ventilation;
- humidity;